


For Sales Only

Customer Information: _____

Item Number: _____



| Available Options | Check If Desired |
|--|--------------------------|
| Downstream Screen in Anodized Aluminum | <input type="checkbox"/> |
| Downstream Screen in Stainless Steel | <input type="checkbox"/> |
| Upstream Gasket | <input type="checkbox"/> |
| Downstream Gasket | <input type="checkbox"/> |
| Both, Upstream and Downstream Gaskets | <input type="checkbox"/> |
| Specify HEPA or ULPA | <input type="checkbox"/> |

| Characteristics | Cleanroom Filter CP-12 |
|-------------------|---|
| Filter Media | Micro-Glass Fiber. |
| Pleat Separator | Continuous String or Hot Melt Glue. |
| Frame Material | Extruded Aluminum. |
| Sealant Material | Polyurethane. |
| Downstream Screen | Expanded Metal, White Powdered Coated. |
| Pleat Depth | 2" |
| Efficiency HEPA | 99.99% min. on 0.3 micron particulate at rated flow |
| Efficiency ULPA | 99.9995% min. on 0.1 - 0.2 micron particulate at rated flow |
| Nominal Size | (Exact Size) - (3/8") |

For Non-Standard Sizes, Please Consult the Factory.

_____ (A) X _____ (B) X _____ 5.25"

Please Specify Size as Nominal or Exact _____

Customer Initial and Date for Non-Standard Size _____


Filtration Group, Inc.
971A Industrial Dr.
Aurora, IL 60506

Cleanroom Filter

CP-12

YOUR APPROVAL OF THIS PRINT AUTHORIZES FILTRATION GROUP, INC. TO PROCEED WITH MATERIAL PROCUREMENT, TOOLING AND PRODUCT FABRICATION. ANY CHANGES MADE AFTER APPROVAL MAY INCUR FURTHER EXPENSES TO THE CUSTOMER.

| | | | | | | | |
|-----|-----|-------|-----------|-----------------|-----------------|-----------|-----------|
| DR: | ARZ | Date: | 11/5/2003 | Drawing Number: | SD-CP-12 | Revision: | 00 |
| CK: | | Date: | | | | | |